

22-NOV-2018 AQI/13:00 (115)

No.	Site	Room No.	Test Time	PM2.5 Mg/m ³
1	PYP back Garden 幼儿园花园	---	12:59 pm	114
2	Soccer Pitch 操场	---	1:27 pm	123
3	GYM 体育馆		12:57 pm	30
4	Library 图书馆	A101	1:03 pm	33
5	PAC Theatre 剧院	---	1:19 pm	37
6	Centre Swimming Pool 泳池	---	1:00 pm	43
7	Cafeteria	---	13:04	29
8	Section B Office B区办公室	B152	1:06 pm	25
9	Section B Classroom B区教室	B153	1:42 pm	37
10	Section C Classroom 主楼C区教室	C109	1:15 pm	31
11	Section D Classroom 主楼D区教室	D206	1:17 pm	23
12	PAC 1F Classroom 东楼一层教室	C146	1:10 pm	36
13	PAC 2F Classroom 东楼二层教室	D240	1:20 pm	33
14	PAC 3F Classroom 东楼三层教室	D348	1:32 pm	38
15	Centre 1F Office 西楼一层办公室	F106	1:40 pm	34
16	Centre 2F Office 西楼二层办公室	G213	1:25 pm	35
17	Centre 2F Classroom 西楼三层教室	H302	2:01 pm	22
18	DT	DT	12:53 pm	21