

**Table 5**  
**WWU Transformers**

| PM #      | BUILDING              | LOCATION                                   | FUEL CAP (gal) | FLUID TYPE      | DIRECTION OF FLOW * | INSIDE/ OUTSIDE | NOTES                       | SECONDARY CONTAINMENT | SECURITY |
|-----------|-----------------------|--|----------------|-----------------|---------------------|-----------------|-----------------------------|-----------------------|----------|
| AHTRAN1   | Amtzen Hall           | C13A                                       | 195            | rtemp oil       | LEVEL               | Inside          | Located on concrete floor   | Yes                   | Yes      |
| BWTRAN1   | Birnam Woods          | West side of rec room                      | 68             | transformer oil | S                   | Outside         | On gravel                   | No                    | Yes      |
| BWTRAN2   | Birnam Woods          | East side of Building 5                    | 68             | transformer oil | SE                  | Outside         | On concrete slab            | No                    | Yes      |
| BWTRAN3   | Birnam Woods          | West side of Building 7                    | 68             | transformer oil | S                   | Outside         | On concrete slab with drain | No                    | Yes      |
| BWTRAN4   | Birnam Woods          | West side of Building 1                    | 68             | transformer oil | SE                  | Outside         | On concrete slab            | No                    | Yes      |
| CVTRAN    | Carver Gym            | Courtyard near Dance Rm                    | 294            | transformer oil | S                   | Outside         | On concrete slab            | No                    | Yes      |
| EHTRAN    | Edens Hall            | Southwest side of building                 | 196            | transformer oil | LEVEL               | Outside         | On concrete                 | No                    | Yes      |
| UTHVSW87  | Edens Hall switch     | Southwest side of building                 | 172            | transformer oil | LEVEL               | Outside         | Next to transformer on pad  | No                    | Yes      |
| ETTRAN    | Engineering Tech      | Room 163                                   | 260            | transformer oil | LEVEL               | Inside          | On concrete                 | Yes                   | Yes      |
| ESTRAN1   | Environmental studies | Room 03                                    | 285            | silicone        | LEVEL               | Inside          | On concrete                 | Yes                   | Yes      |
| FATRAN1   | Fairhaven Acad        | Room ER-1                                  | 110            | silicone        | LEVEL               | Inside          | On concrete                 | Yes                   | Yes      |
| FCTRAN1   | Fairhaven #1          | Between Stack 1 and 2                      | 68             | transformer oil | SW                  | Outside         | On concrete with drain      | No                    | Yes      |
| FCTRAN2   | Fairhaven #2          | Between Stack 3 and 4                      | 68             | transformer oil | W                   | Outside         | On concrete with drain      | No                    | Yes      |
| FCTRAN3   | Fairhaven #3          | Between Stack 5 and 6                      | 68             | transformer oil | W                   | Outside         | On concrete with drain      | No                    | Yes      |
| FCTRAN4   | Fairhaven #4          | Next to Stack 9                            | 68             | transformer oil | LEVEL               | Outside         | On concrete with drain      | No                    | Yes      |
| FCTRAN5   | Fairhaven #5          | Next to Stack 11                           | 68             | transformer oil | SE                  | Outside         | On concrete with drain      | No                    | Yes      |
| HITRAN    | Highland Lounge       | Located on North side                      | 133            | transformer oil | N                   | Outside         | On concrete slab            | No                    | Yes      |
| MCTRAN1   | Marine center lab     | South west side of building                | 190            | transformer oil | N                   | Outside         | On grass                    | No                    | Yes      |
| MCTRAN2   | Marine center Housing | North side of housing                      | 107            | transformer oil | N                   | Outside         | On grass                    | No                    | Yes      |
| MCTRAN3   | Marine center Utility | West side of main road b/w housing and lab | 180            | transformer oil | W                   | Outside         | On grass                    | No                    | Yes      |
| SF-MC-H-2 | Marine center Switch  | At the entrance of the housing driveway    | 363            | transformer oil | W                   | Outside         | On grass                    | No                    | Yes      |
| NATRAN    | Nash Hall             | Rm 9 - Electrical Vault                    | 75             | transformer oil | LEVEL               | Inside          | On concrete floor           | Yes                   | Yes      |
| NATRAN    | Nash Hall             | Rm 9 - Electrical Vault                    | 75             | transformer oil | LEVEL               | Inside          | On concrete floor           | Yes                   | Yes      |
| NATRAN    | Nash Hall             | Rm 9 - Electrical Vault                    | 75             | transformer oil | LEVEL               | Inside          | On concrete floor           | Yes                   | Yes      |
| OMTRAN1   | Old Main South        | Rm 104B - Electrical Vault                 | 330            | transformer oil | E                   | Inside          | On concrete slab            | Yes                   | Yes      |
| OMTRAN2   | Old Main North        | Rm 104B - Electrical                       | 210            | transformer oil | NW                  | Inside          | On concrete slab            | Yes                   | Yes      |

|         |                        | Vault                                   |        |                 |       |         |                  |    |     |
|---------|------------------------|---|--------|-----------------|-------|---------|------------------|----|-----|
| PHTRAN  | Parks Hall             | Under stairs b/w Pks and Hux            | 200    | transformer oil | NW    | Outside | On concrete slab | No | Yes |
| SPTRAN1 | Steam Plant #1         | NW side of Steam Plant                  | 190    | transformer oil | N     | Outside | On concrete slab | No | Yes |
| SPTRAN2 | Steam Plant #2         | NW side of Steam Plant                  | 1650   | transformer oil | SE    | Outside | On concrete slab | No | Yes |
| RXTRAN1 | Ridgeway Transformer 1 | Next to Beta and Gamma                  | 200app | transformer oil | NE    | Outside | On concrete slab | No | Yes |
| RXTRAN2 | Ridgeway Transformer 2 | Next to Kappa's Tennis Courts           | 200app | transformer oil | N     | Outside | On concrete slab | No | Yes |
| RXTRAN3 | Ridgeway Transformer 3 | South side of Delta                     | 200app | transformer oil | E     | Outside | On concrete slab | No | Yes |
| RXTRAN4 | Ridgeway Transformer 4 | South side of Sigma                     | 200app | transformer oil | E     | Outside | On concrete slab | No | Yes |
| RXTRAN5 | Ridgeway Transformer 5 | Next to commons                         | 200app | transformer oil | W     | Outside | On concrete slab | No | Yes |
| RXTRAN6 | Ridgeway Transformer 6 | Next to Highland Lounge                 | 200app | transformer oil | LEVEL | Outside | On concrete slab | No | Yes |
| TCTRAN  | Tennis Courts          | East of Tennis Courts by Softball Field |        | Mineral oil     | S     | Outside | On concrete slab | No | Yes |