

**TASK OUTLINE**

Effective Date: 01/04/2000, Revised 04/27/07

Approved By: Director of Facilities Management

Authority: RCW Title 49 and Title 70

Cancels: FM 89-8

See Also: POL-U5950.01, POL-U5950.05,  
and POL-U5950.06**TSK-FM5950.01D RE-LAMPING IN LIMITED ACCESS AREAS  
(For Example, Tunnels, Mechanical Spaces, Crawl Spaces)**

The Facilities Management **Maintenance Mechanic** or **Electrician** shall do the following:

1. When re-lamping a light fixture located 6 feet or less from the floor in a limited access area, **use** a **shatter-proof** lamp or other shatter-proof device.
2. When re-lamping a light fixture within contact distance of a fixed ladder in any limited access area, **use** a shatter-proof lamp or other shatter-proof device.
3. **Use** “common sense” when applying the above.
4. **Follow** the appropriate procedure or task outline that pertains to changing lamps and ballasts.